



NOTES:

1. MANHOLE WALLS SHALL BE SOUNDED WITH A HAMMER, AND ALL VOIDS SHALL BE FILLED WITH GROUT AS PER SS-7.
2. MANHOLE WALLS TO BE CLEANED, PATCHED, AND LINED PER SS-10.
3. THE CONTRACTOR SHALL PLACE A DEVICE IN THE MANHOLE TO CATCH ANY DEBRIS WHICH MAY FALL INTO THE MANHOLE DURING PERFORMANCE OF WORK. ALL MATERIAL RESULTING FROM THE CLEANING AND/OR REPAIR OF THE REPAIR OF THE MANHOLE SHALL BE REMOVED AND PROPERLY DISPOSED.

CITY OF COLUMBUS, OHIO
DEPARTMENT OF PUBLIC UTILITIES
DIVISION OF SEWERAGE & DRAINAGE

PRE-CAST MANHOLE
REHABILITATION

STANDARD DRAWING
AA-S173

REVISED 7/9/12

SSS MANAGER

John J. Newson

PAGE

1

1